

CCW® Armored Instrumentation, Pairs/Triads, Overall Shield

UL Type MC-HL, PVC/Nylon, 600 V, 90°C, Cable Tray Use, Sunlight-Resistant, Direct Burial
UL Marine Shipboard Cable, ABS CWCMC



Product Construction:

Conductor:

- Bare annealed copper per ASTM B3
- Class B stranding per ASTM B8

Insulation:

- Flame-retardant Polyvinyl Chloride (PVC) insulation and nylon covering, rated 90°C per UL Standard 83
- Color-coded per ICEA Method 1: pairs – black and white; triads – black, white and red. Each conductor in each pair or triad is printed alphanumerically for easy identification

Cable Assembly:

- Individual pairs or triads are cabled together with a left-hand lay

Overall Shield:

- Flexfoil® aluminum/polyester tape shield providing 100% coverage
- Stranded tinned copper drain wire, same size as insulated conductors

Inner Jacket:

- Flame-retardant Polyvinyl Chloride (PVC) per UL Standard 1569, black
- Low temperature performance meets ASTM D746 brittleness temperature at or below -40°C
- Nylon rip cord to facilitate jacket removal

CCW Armor:

- Impervious, continuously welded and corrugated aluminum alloy sheath per UL Standards 1569 and 2225
- CCW armor conductivity meets the grounding requirements of NEC Article 250

Overall Jacket:

- Flame-retardant, moisture- and sunlight-resistant Polyvinyl Chloride (PVC) per UL Standard 1569, black
- Low temperature performance meets ASTM D746 brittleness temperature at or below -40°C

Applications:

- CCW armored 600 volt instrumentation cables with an overall shield provide superior protection and reliability against physical damage for use in instrumentation and process control applications where shielding against external EMI is required
- For use in Class 1 remote-control and signal circuits in accordance with NEC Article 725
- Recognized for use in Class I, II and III, Divisions 1 and 2; or Class I, Zones 1 and 2 hazardous locations per NEC Articles 501, 502, 503 and 505
- Installed indoors or outdoors, in wet or dry locations, in a raceway, as aerial cable on a messenger, in cable trays, or for direct burial
- Recognized for use on fixed or floating offshore petroleum facilities as recommended by the American Petroleum Institute

Features:

- CCW armor provides superior mechanical protection and an impervious barrier to moisture, gas and liquids
- CCW armor provides EMI shielding performance
- Meets cold bend and cold impact at -40C

Specifications:

Design Adherence:

- UL 83 Thermoplastic Insulated Wire and Cables
- UL 1569 Metal Clad Cables
- UL 2225 Cables and Cable Fittings for Use in Hazardous Locations
- UL 1309/CSA C22.2 No. 245 Marine Shipboard Cable

Flame Tests:

- IEEE 383 (70,000 BTU/hr)
- CSA FT4
- IEEE 1202 (70,000 BTU/hr)

Compliances:

- UL Type MC-HL, CT USE, SUN RES, DIR BUR, -40°C, UL File # E90496
- UL Listed Marine Shipboard, UL File # E85994
- American Bureau of Shipping (ABS) Listed for CWCMC
- RoHS Compliant

CCW® Armored Instrumentation, Pairs/Triads, Overall Shield

UL Type MC-HL, PVC/Nylon, 600 V, 90°C, Cable Tray Use, Sunlight-Resistant, Direct Burial
UL Marine Shipboard Cable, ABS CWCMC

CATALOG NUMBER	COND. SIZE (AWG)	NO. OF PAIRS	INSULATION THICKNESS		INNER JACKET THICKNESS		NOMINAL CORE O.D.		NOMINAL ARMOR O.D.		JACKET THICKNESS		NOMINAL OVERALL O.D.		CROSS-SECTIONAL AREA ¹ SQ. IN.	APPROXIMATE NET WEIGHT	
			mils	mm	mils	mm	IN	mm	IN	mm	mils	mm	IN	mm		LBS/1000 FT	kg/1000 m

18 AWG 7W (0.82 mm²) OVERALL SHIELDED PAIRS

9325.18020001	18	2	19	0.48	40	1.02	0.41	10.4	0.59	15.0	50	1.27	0.70	17.8	0.38	222	330
9325.18040001	18	4	19	0.48	40	1.02	0.48	12.2	0.65	16.5	50	1.27	0.75	19.1	0.44	268	399
9325.18080001	18	8	19	0.48	50	1.27	0.60	15.2	0.82	20.8	50	1.27	0.92	23.4	0.66	420	625
9325.18120001	18	12	19	0.48	50	1.27	0.78	19.8	1.00	25.4	50	1.27	1.10	27.9	0.95	560	833
9325.18160001	18	16	19	0.48	50	1.27	0.81	20.6	1.12	28.4	50	1.27	1.23	31.2	1.19	706	1051
9325.18240001	18	24	19	0.48	50	1.27	1.08	27.4	1.39	35.3	50	1.27	1.49	37.8	1.74	969	1442

16 AWG 7W (1.31 mm²) OVERALL SHIELDED PAIRS

9325.16010001	16	1	19	0.48	40	1.02	0.29	7.3	0.45	11.5	50	1.27	0.56	14.2	0.24	169	251
9325.16020001	16	2	19	0.48	40	1.02	0.42	10.7	0.60	15.2	50	1.27	0.71	17.9	0.39	240	357
9325.16040001	16	4	19	0.48	40	1.02	0.49	12.4	0.70	17.9	50	1.27	0.81	20.5	0.51	318	473
9325.16060001	16	6	19	0.48	50	1.27	0.58	14.7	0.80	20.3	50	1.27	0.91	23.1	0.65	405	603
9325.16080001	16	8	19	0.48	50	1.27	0.66	16.8	0.89	22.6	50	1.27	1.00	25.4	0.79	466	693
9325.16100001	16	10	19	0.48	50	1.27	0.76	19.3	1.02	25.9	50	1.27	1.13	28.7	1.00	556	827
9325.16120001	16	12	19	0.48	50	1.27	0.80	20.3	1.06	26.9	50	1.27	1.17	29.7	1.08	604	899
9325.16160001	16	16	19	0.48	50	1.27	0.88	22.4	1.12	28.5	50	1.27	1.23	31.2	1.18	756	1125
9325.16200001	16	20	19	0.48	50	1.27	0.98	24.9	1.29	32.8	50	1.27	1.40	35.6	1.54	929	1383
9325.16240001	16	24	19	0.48	50	1.27	1.08	27.4	1.37	34.8	50	1.27	1.48	37.6	1.72	1040	1548
9325.16360001	16	36	19	0.48	50	1.27	1.32	33.5	1.64	41.7	60	1.52	1.78	45.2	2.49	1445	2150
9325.16500001	16	50	19	0.48	50	1.27	1.48	37.6	1.83	46.5	60	1.52	1.96	49.8	3.02	1897	2823

CATALOG NUMBER	COND. SIZE (AWG)	NO. OF PAIRS	INSULATION THICKNESS		INNER JACKET THICKNESS		NOMINAL CORE O.D.		NOMINAL ARMOR O.D.		JACKET THICKNESS		NOMINAL OVERALL O.D.		CROSS-SECTIONAL AREA ¹ SQ. IN.	APPROXIMATE NET WEIGHT	
			mils	mm	mils	mm	IN	mm	IN	mm	mils	mm	IN	mm		LBS/1000 FT	kg/1000 m

16 AWG 7W (1.31 mm²) OVERALL SHIELDED TRIADS

9325.16010002	16	1	19	0.48	40	1.02	0.33	8.4	0.51	13.0	50	1.27	0.61	15.6	0.30	203	301
9325.16040002	16	4	19	0.48	40	1.02	0.51	13.0	0.71	18.0	50	1.27	0.82	20.8	0.53	407	606
9325.16080002	16	8	19	0.48	50	1.27	0.71	18.0	0.93	23.6	50	1.27	1.04	26.4	0.85	617	918
9325.16120002	16	12	19	0.48	50	1.27	0.85	21.6	1.11	28.2	50	1.27	1.22	31.0	1.17	897	1335
9325.16160002	16	16	19	0.48	50	1.27	0.93	23.6	1.19	30.2	50	1.27	1.30	33.0	1.33	1161	1728
9325.16240002	16	24	19	0.48	50	1.27	1.16	29.5	1.47	37.3	50	1.27	1.58	40.1	1.96	1581	2353
9325.16360002	16	36	19	0.48	50	1.27	1.42	36.1	1.74	44.2	60	1.52	1.87	47.5	2.75	2142	3188

Dimensions and weights are nominal; subject to industry tolerances.

¹ Cross-sectional area for cable tray fill is in accordance with NEC® Section 392.22.

